

# ATTESTATION OF CONFORMITY

Issued to: MEGA TECHNOLOGY (ZHENJIANG) CO., LTD.  
4F, Ganglong Road, Economic Development Zone, Science and Technology Building, Yangzhong City, Jiangsu Province, China

For the product: Low-voltage busbar trunking system (copper bar)

Trade name: OPTIMUS

Type/Model: OPTIMUS1000A, OPTIMUS1250A, OPTIMUS1600A, OPTIMUS2500A (with/without tap-off unit outlet), OPTIMUS5000A (without tap-off unit outlet)

Ratings: Ue: 690 V, 50/60 Hz, Ie: 1000 A, 1250 A, 1600 A, 2500 A and 5000 A  
Icw: 3-phase 63 kA / 1 s (1000 A, 1250 A, 1600A), 80 kA / 1 s (2500 A), 100 kA / 1 s (5000 A),  
Neutral / PE 37,8 kA / 1 s (1000 A, 1250 A, 1600A), 48 kA / 1 s (2500 A), 60 kA / 1 s (5000 A)  
IP66 for BTS without TOU outlet, IP55 for 2500 A BTS with TOU outlet, Further ratings see annex

Manufactured by: MEGA TECHNOLOGY (ZHENJIANG) CO., LTD.  
4F, Ganglong Road, Economic Development Zone, Science and Technology Building, Yangzhong City, Jiangsu Province, China

Subject: Type test

Requirements: EN 61439-6:2012, IEC 61439-6:2012

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in report no 3304861.01-INC issued on 2013-05-27 and 3302814.01/05 issued on 2012-04-05.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2006/95/EC.


The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Wenzhou, Zhejiang, 23 April 2015

Number: 3307767.01A

DEKRA Testing Services (Zhejiang) Ltd.

Ms J Guo  
Certification Manager



© Integral publication of this attestation and adjoining reports is allowed  
The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

