

ATTESTATION OF CONFORMITY

Issued to: MEGA TECHNOLOGY (ZHENJIANG) CO., LTD
No. 3, Yuanbo Avenue, Economic Development Area, Yangzhong City, Jiangsu,
China

For the product: Low-voltage Busbar trunking system (aluminium bar)

Trade name: OPTIMUS

Type/Model: OPTIMUS 800 A / 1000 A / 1350 A / 1600 A / 2000 A

Ratings: Ue: 1000 V, 50/60 Hz, I_{nA}: 800 A, 1000 A, 1350 A, 1600 A, 2000 A
Icw: 3-phase: 35 kA / 1 s (800 A), 50 kA / 1 s (1000 A), 80 kA / 1 s (1350 A, 1600 A),
85 kA / 1 s (2000 A)
Neutral bar and PE bar: 60% of phase bar / 1 s
IP66
Further ratings see annex

Manufactured by: MEGA TECHNOLOGY (ZHENJIANG) CO., LTD
No. 3, Yuanbo Avenue, Economic Development Area, Yangzhong City, Jiangsu,
China

Subject: Design verification

Requirements: EN 61439-6:2012, IEC 61439-6:2012

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test reports no. 3309862.50/51/52 issued on 15 June 2016, 3309987.50 issued on 15 June 2016 and 3310164.50 issued on 27 July 2016.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Wenzhou, Zhejiang, 31 October 2016 Number: 3310845.01A

DEKRA Testing Services (Zhejiang) Co., Ltd.

Ms J Guo
Certification Manager



© Integral publication of this attestation and adjoining reports is allowed
The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

DEKRA Testing Services (Zhejiang) Co., Ltd.
No. 5, Changjiang Road Great Bridge Industrial Park North Baixiang, Wenzhou, Zhejiang, 325603, P. R. China
T +86577628680 00 F +86577629198 89 www.dekra-certification.com